

TANK-AXONOMETRIC

TANK COMPONENTS				
No.	Description	Material	Qty	Remarks
1	Water tank	FRP	1	Colour GRAY
2	Manhole Cover	FRP	1	S/S Hinges & Locks
3	Internal Ladder	FRP/SS	1	Height : 2m
4	External Ladder	G.I.	1	Height : 2m
5	Air vent	PVC	1	Light & Insect Proof 4" Cow Type
6	Inlet		1	PVC or FF Steel Threaded Flange
7	Outlet		1	PVC or FF Steel Threaded Flange
8	Drainage		1	PVC or FF Steel Threaded Flange
9	Overflow		1	PVC or FF Steel Threaded Flange
10	Control		1	PVC or FF Steel Threaded Flange
11	Water Level Indicator	GRP/ACRYLIC	1	Height : 2m
12	Vortex Assembly	FRP	1	-
13	Side Man Way	FRP	1	-

- NOTES:**
- CAUTIONS**
1. Allow a minimum space of 50 cm all around the tank's foundation.
 2. Maximum allowable deflection in concrete foundation = +/- 2mm.
 3. For sizes of items 6, 7, 8, 9 & 10, please refer to catalogue.
 4. FTC will not be held liable if the erection of our water tanks are not made in accordance to the technical requirements of concrete foundation, steel footing and water tank assembly drawings.
 5. Overflow shall be minimum twice the volume of inlet.
 6. Overflow shall flow freely to the ground.
 7. All tanks shall be electrically grounded.

GRP Panel Type Water Tanks			
Seismic Load Kh=0.3G			
Tank size:	6.56x 6.56x 6.56 ft High. 2x2x2 m HIGH		
Volume:	8 m ³	2113. USG	Usable 1620
Bolts / Nuts:	S/S A4 - 316		
Insulation:	Non-Insulated		

Project Name:
-


Contractor:
Cougar USA

Consultant:
-

Done By: JC Reviewed by:
Verified by: -

Revisions		
No.	Issue Date	Description
0	-	NEW

FTC FIBER TECHNOLOGY CORPORATION
 Head Office:
 Lorton, Virginia, United States of America
 Regional Office:
 Jebel Ali Free Zone, Dubai, U.A.E.



STEEL FOOTING-PLAN

TANK COMPONENTS				
No.	Description	Material	Qty	Remarks
1	Water tank	FRP	1	Colour GRAY
2	Manhole Cover	FRP	1	S/S Hinges & Locks
3	Internal Ladder	FRP/SS	1	Height : 2m
4	External Ladder	G.I.	1	Height : 2m
5	Air vent	PVC	1	Light & Insect Proof 4" Cow Type
6	Inlet		1	PVC or FF Steel Threaded Flange
7	Outlet		1	PVC or FF Steel Threaded Flange
8	Drainage		1	PVC or FF Steel Threaded Flange
9	Overflow		1	PVC or FF Steel Threaded Flange
10	Control		1	PVC or FF Steel Threaded Flange
11	Water Level Indicator	GRP/ACRYLIC	1	Height : 2m
12	Vortex Assembly	FRP	1	-
13	Side Man Way	FRP	1	-

- NOTES:**
- CAUTIONS**
1. Allow a minimum space of 50 cm all around the tank's foundation.
 2. Maximum allowable deflection in concrete foundation = +/- 2mm.
 3. For sizes of items 6, 7, 8, 9 & 10, please refer to catalogue.
 4. FTC will not be held liable if the erection of our water tanks are not made in accordance to the technical requirements of concrete foundation, steel footing and water tank assembly drawings.
 5. Overflow shall be minimum twice the volume of inlet.
 6. Overflow shall flow freely to the ground.
 7. All tanks shall be electrically grounded.

GRP Panel Type Water Tanks			
Seismic Load Kh=0.3G			
Tank size:	6.56x 6.56x 6.56 ft High. 2x2x2 m HIGH		
Volume:	8 m ³	2113. USG	Usable 1620
Bolts / Nuts:	S/S A4 - 316		
Insulation:	Non-Insulated		

Project Name:
-

Contractor:
Cougar USA

Consultant:
-


Done By: JC Reviewed by:
Verified by: -

Revisions		
No.	Issue Date	Description
0	-	NEW

FTC FIBER TECHNOLOGY CORPORATION

Head Office:
Lorton, Virginia, United States of America

Regional Office:
Jebel Ali Free Zone, Dubai, U.A.E.



TANK-PLAN

TANK COMPONENTS				
No.	Description	Material	Qty	Remarks
1	Water tank	FRP	1	Colour GRAY
2	Manhole Cover	FRP	1	S/S Hinges & Locks
3	Internal Ladder	FRP/SS	1	Height : 2m
4	External Ladder	G.I.	1	Height : 2m
5	Air vent	PVC	1	Light & Insect Proof 4" Cow Type
6	Inlet		1	PVC or FF Steel Threaded Flange
7	Outlet		1	PVC or FF Steel Threaded Flange
8	Drainage		1	PVC or FF Steel Threaded Flange
9	Overflow		1	PVC or FF Steel Threaded Flange
10	Control		1	PVC or FF Steel Threaded Flange
11	Water Level Indicator	GRP/ACRYLIC	1	Height : 2m
12	Vortex Assembly	FRP	1	-
13	Side Man Way	FRP	1	-

- NOTES:**
- CAUTIONS**
1. Allow a minimum space of 50 cm all around the tank's foundation.
 2. Maximum allowable deflection in concrete foundation = +/- 2mm.
 3. For sizes of items 6, 7, 8, 9 & 10, please refer to catalogue.
 4. FTC will not be held liable if the erection of our water tanks are not made in accordance to the technical requirements of concrete foundation, steel footing and water tank assembly drawings.
 5. Overflow shall be minimum twice the volume of inlet.
 6. Overflow shall flow freely to the ground.
 7. All tanks shall be electrically grounded.

GRP Panel Type Water Tanks			
Seismic Load Kh=0.3G			
Tank size:	6.56x 6.56x 6.56 ft High. 2x2x2 m HIGH		
Volume:	8 m ³	2113 USG	Usable 1620
Bolts / Nuts:	S/S A4 - 316		
Insulation:	Non-Insulated		

Project Name:
-

Contractor:
Cougar USA

Consultant:
-

Done By: JC Reviewed by:
Verified by: -


Revisions		
No.	Issue Date	Description
0	-	NEW

FTC FIBER TECHNOLOGY CORPORATION

Head Office:
Lorton, Virginia, United States of America

Regional Office:
Jebel Ali Free Zone, Dubai, U.A.E.

Copyright Fiber Technology Corporation



FRONT ELEVATION

TANK COMPONENTS				
No.	Description	Material	Qty	Remarks
1	Water tank	FRP	1	Colour GRAY
2	Manhole Cover	FRP	1	S/S Hinges & Locks
3	Internal Ladder	FRP/SS	1	Height : 2m
4	External Ladder	G.I.	1	Height : 2m
5	Air vent	PVC	1	Light & Insect Proof 4' Cow Type
6	Inlet		1	PVC or FF Steel Threaded Flange
7	Outlet		1	PVC or FF Steel Threaded Flange
8	Drainage		1	PVC or FF Steel Threaded Flange
9	Overflow		1	PVC or FF Steel Threaded Flange
10	Control		1	PVC or FF Steel Threaded Flange
11	Water Level Indicator	GRP/ACRYLIC	1	Height : 2m
12	Vortex Assembly	FRP	1	-
13	Side Man Way	FRP	1	-

NOTES:

CAUTIONS

1. Allow a minimum space of 50 cm all around the tank's foundation.
2. Maximum allowable deflection in concrete foundation = +/- 2mm.
3. For sizes of items 6, 7, 8, 9 & 10, please refer to catalogue.
4. FTC will not be held liable if the erection of our water tanks are not made in accordance to the technical requirements of concrete foundation, steel footing and water tank assembly drawings.
5. Overflow shall be minimum twice the volume of inlet.
6. Overflow shall flow freely to the ground.
7. All tanks shall be electrically grounded.

GRP Panel Type Water Tanks
Seismic Load Kh=0.3G

Tank size:	6.56x 6.56x 6.56 ft High. 2x2x2 m HIGH		
Volume:	8 m ³	2113 USG	Usable 1620
Bolts / Nuts:	S/S A4 - 316		
Insulation:	Non-Insulated		

Project Name: -

Contractor: Cougar USA

Consultant: -


Done By:	JC	Reviewed by:	
Verified by:			

Revisions

No.	Issue Date	Description
0	-	NEW

FTC FIBER TECHNOLOGY CORPORATION
 Head Office:
 Lorton, Virginia, United States of America
 Regional Office:
 Jebel Ali Free Zone, Dubai, U.A.E.

Copyright Fiber Technology Corporation



TANK-RIGHT ELEVATION

TANK COMPONENTS

No.	Description	Material	Qty	Remarks
1	Water tank	FRP	1	Colour GRAY
2	Manhole Cover	FRP	1	S/S Hinges & Locks
3	Internal Ladder	FRP/SS	1	Height : 2m
4	External Ladder	G.I.	1	Height : 2m
5	Air vent	PVC	1	Light & Insect Proof 4" Cow Type
6	Inlet		1	PVC or FF Steel Threaded Flange
7	Outlet		1	PVC or FF Steel Threaded Flange
8	Drainage		1	PVC or FF Steel Threaded Flange
9	Overflow		1	PVC or FF Steel Threaded Flange
10	Control		1	PVC or FF Steel Threaded Flange
11	Water Level Indicator	GRP/ACRYLIC	1	Height : 2m
12	Vortex Assembly	FRP	1	-
13	Side Man Way	FRP	1	-

NOTES:

CAUTIONS

1. Allow a minimum space of 50 cm all around the tank's foundation.
2. Maximum allowable deflection in concrete foundation = +/- 2mm.
3. For sizes of items 6, 7, 8, 9 & 10, please refer to catalogue.
4. FTC will not be held liable if the erection of our water tanks are not made in accordance to the technical requirements of concrete foundation, steel footing and water tank assembly drawings.
5. Overflow shall be minimum twice the volume of inlet.
6. Overflow shall flow freely to the ground.
7. All tanks shall be electrically grounded.

GRP Panel Type Water Tanks

Seismic Load Kh=0.3G

Tank size:	6.56x 6.56x 6.56 ft High. 2x2x2 m HIGH		
Volume:	8 m ³	2113. USG	Usable 1620
Bolts / Nuts:	S/S A4 - 316		
Insulation:	Non-Insulated		

Project Name:

-

Contractor:

Cougar USA

Consultant:

-

Done By: JC

Reviewed by:

Verified by: -

Revisions

No.	Issue Date	Description
0	-	NEW



Head Office:
Lorton, Virginia, United States of America

Regional Office:
Jebel Ali Free Zone, Dubai, U.A.E.